

**YUKON WATER BOARD
AMENDMENT OF LICENCE**

LICENSEE: YUKON ENERGY CORPORATION

LICENCE NUMBER: HY99-012

AMENDMENT NUMBER: One (1)

Application Number: HY07-016


Pursuant to the *Waters Act*, Water Use Licence HY99-012 is hereby amended as follows:

1. The following section is hereby added:


PART C - SPECIAL MAINTENANCE

27. During the period of November 8, 2007 to November 22, 2007 inclusive, the Licensee is authorized to reduce or eliminate the minimum instantaneous flow of 2.8 cubic metres per second (100 cubic feet per second) in the channels downstream of the Mayo Lake Dam and the Wareham Lake Powerhouse, in order to carry out maintenance of the outlet valves in the Mayo Lake Dam.
28. The Licensee shall conduct the work as described in application HY07-016.
29. No less than 48 hours prior to initiating the maintenance work, the Licensee shall notify the Board of its intent to do so. The notice will include confirmation that notice has also been provided to Fisheries and Oceans Canada and Government of Yukon, Environment.
30. No reduction or elimination of the minimum instantaneous flow shall exceed a continuous duration of more than four hours.
31. The Licensee shall provide weekly reports to the Board documenting the maintenance work carried out during the preceding week, the minimum instantaneous flows maintained, and any fish salvage and relocation carried out.


Issued this 9th day of
November, 2007



Witness

YUKON WATER BOARD


Chairperson

Approved this 9th day of
November, 2007


Witness


A/Minister, Executive Council Office