

**YUKON WATER BOARD
AMENDMENT OF LICENCE**

LICENSEE: WAYNE FISCHER

LICENCE: PM05-493

AMENDMENT NUMBER: 1


APPLICATION NUMBER: PM08-606

Pursuant to the *Waters Act*, Water Use Licence PM05-493 is hereby amended as follows:


1. **Clause 3 of this licence is hereby withdrawn.**
2. **Clause 7 of this licence is hereby withdrawn.**
3. **Clause 5 of this licence is hereby withdrawn and replaced by:**
 5. Effluent Quality Standard: The Licensee shall comply with the Category A, Freshwater Fisheries Production Zone effluent discharge standards for any grab sample taken at the point in the effluent flow immediately before it enters the natural stream flow, as follows:
 - a) The Design Target for effluent discharge shall be 0.2 ml/L; and
 - b) The Action Level for effluent discharge shall be 1.0 ml/L; and
 - c) The Compliance Level for effluent discharge shall be 1.5 ml/L; and
 - d) All effluent discharge levels included in this licence are identified in excess of natural background concentrations in the Watercourse at the time of sampling.

Approved this 21 day of

April, 2010.



Witness



Chairperson
Yukon Water Board