

**YUKON WATER BOARD  
AMENDMENT OF LICENCE**

LICENSEE: FAVRON ENTERPRISES LTD.

LICENCE NUMBER: PM06-519

AMENDMENT NUMBER: ONE (1)

Application Number: PM08-610

Pursuant to the Waters Act, Water Use Licence PM06-519, is hereby amended as follows:

**1. Clause 5 is hereby withdrawn and replaced by:**

Effluent Quality Standard: The Licensee shall comply with the following effluent discharge standards for any grab sample taken at the point in the effluent flow immediately before it enters the natural stream flow:

- a) the Design Target for effluent discharge shall be 0.2 ml/L; and
- b) the Action Level for effluent discharge shall be 1.0 ml/L; and
- c) the Compliance Level for effluent discharge shall be 2.5 ml/L for 5 years after the effective date of this amendment; then
- d) the Compliance Level for effluent discharge shall be 2.0 ml/L.

**2. Clause 29 is hereby added:**

Where there is a surface discharge from the settling facilities, the Licensee shall take weekly samples at a point upstream of the water supply intake and at a point in the effluent flow immediately before it enters the natural stream flow, and shall analyze these samples for settleable solids using the Imhoff cone 1 hour test or laboratory analysis.


Dated this 18 day of

Approved by:

December, 2008

SBrid

Witness



Chairperson

YUKON WATER BOARD